



TEST REPORT

Report No.: F6419.01-301-44

Rendered to:

TAM SKYLIGHTS
Seattle, Washington

PRODUCT TYPE: Skylight
SERIES/MODEL: Fixed Dome / DDP

SPECIFICATION(S):

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class CW-PG-40-1230 x 2450 mm (48 x 96in)- Type SKP/RW
Design Pressure	±1920 Pa (±40.10 psf)
Air Infiltration	0.1 L/s/m ² (0.02 cfm/ft ²)
Water Penetration Resistance Test Pressure	580 Pa (12.11 psf)

Test Completion Date: 04/20/16

Reference must be made to Report No. F6419.01-301-44, dated 09/23/16 for complete test specimen description and detailed test results.